

English Version

Low-voltage surge protective devices -
Part 22: Surge protective devices connected to
telecommunications and signalling networks - Selection and
application principles
(IEC 61643-22:2015 , modified)

Parafoudres basse tension -
Partie 22: Parafoudres connectés aux réseaux de signaux
et de télécommunications - Principes de choix et
d'application
(IEC 61643-22:2015 , modifiée)

Überspannungsschutzgeräte für Niederspannung -
Teil 22: Überspannungsschutzgeräte für den Einsatz in
Telekommunikations- und signalverarbeitenden Netzwerken
- Auswahl und Anwendungsprinzipien
(IEC 61643-22:2015 , modifiziert)

This Technical Specification was approved by CENELEC on 2016-02-29.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

This document (CLC/TS 61643-22:2016) consists of the text of IEC 61643-22:2015 prepared by SC 37A "Low-voltage surge protective devices" of IEC/TC 37 "Surge arresters", together with the common modifications prepared by CLC/TC 37A "Low voltage surge protective devices".

This document supersedes CLC/TS 61643-22:2006.

CLCTS 61643-22:2016 includes the following significant technical changes with respect to CLC/TS 61643-22:2006:

- a) Update the use of multiservice SPDs (Article 8)
- b) Comparison between SPD classification of EN 61643-11 and EN 61643-21 (7.3.3)
- c) Consideration of new transmission systems as PoE (Annex F)
- d) EMC requirements of SPDs (Annex G)
- e) Maintenance cycles of SPDs (Annex I)

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61643-22:2015 was approved by CENELEC as a European Standard with agreed common modifications.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references.....	10
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions	11
3.2 Abbreviations	11
4 Description of technologies	11
4.1 General.....	11
4.2 Voltage-limiting components.....	11
4.2.1 General	11
4.2.2 Clamping components.....	12
4.2.3 Switching components.....	12
4.3 Current-limiting components	12
4.3.1 General	12
4.3.2 Current-interrupting components	12
4.3.3 Current-reducing components.....	12
4.3.4 Current-diverting components.....	12
5 Parameters for selection of SPDs and appropriate tests from IEC 61643-21	13
5.1 General.....	13
5.2 Normal service conditions	13
5.2.1 General	13
5.2.2 Air pressure and altitude	13
5.2.3 Ambient temperature.....	13
5.2.4 Relative humidity	13
5.2.5 Abnormal service conditions.....	13
5.3 SPD parameters that may affect normal system operation.....	13
6 Risk management.....	14
6.1 General.....	14
6.2 Risk analysis.....	15
6.3 Risk identification.....	15
6.4 Risk treatment.....	15
7 Application of SPDs	17
7.1 General.....	17
7.2 Coupling mechanisms	17
7.3 Application, selection and installation of surge protective devices (SPDs).....	19
7.3.1 Application requirements for SPDs	19
7.3.2 SPD installation cabling considerations	23
7.3.3 Comparison between SPD classification of IEC 61643-11 and IEC 61643-21.....	26
8 Multiservice surge protective devices	26
9 Coordination of SPDs/ITE	29
Annex A (informative) Voltage-limiting components	30
A.1 Clamping components	30
A.1.1 General	30
A.1.2 Metal oxide varistor (MOV).....	30

A.1.3	Silicon semi-conductors	30
A.2	Switching components.....	32
A.2.1	General	32
A.2.2	Gas discharge tube (GDT).....	32
A.2.3	Air gaps	32
A.2.4	Thyristor surge suppressor (TSS) – Fixed voltage types (self-gating)	33
A.2.5	Thyristor surge suppressor (TSS) – Gated types	33
Annex B (informative)	Current-limiting components.....	34
B.1	General.....	34
B.2	Non-resetting current limiters	34
B.2.1	General	34
B.2.2	Series current-interrupting components	34
B.2.3	Shunt current-diverting limiters.....	35
B.3	Self-resetting current limiters.....	37
B.3.1	General	37
B.3.2	Series current-reducing components.....	37
B.3.3	Shunt current-diverting components	39
Annex C (informative)	Risk management.....	40
C.1	Risk due to lightning discharges	40
C.1.1	Risk assessment.....	40
C.1.2	Risk analysis.....	40
C.1.3	Risk treatment	42
C.2	Risk due to power line faults.....	43
C.2.1	General	43
C.2.2	AC power systems	43
C.2.3	DC power systems	43
Annex D (informative)	Transmission characteristics related to IT systems	45
D.1	General.....	45
D.2	Telecommunications systems	45
D.3	Signalling, measurement and control systems.....	46
D.4	Cable TV systems	46
Annex E (informative)	Coordination of SPDs/ITE	47
E.1	General.....	47
E.2	Determination of U_{IN} and I_{IN}	47
E.3	Determine the output protective voltage and current waveforms for SPD1	48
E.4	Compare SPD1 and SPD2 values	48
E.5	Necessity of verification of the coordination by testing	49
Annex F (informative)	Protection of Ethernet systems	50
F.1	Power over Ethernet (PoE).....	50
F.2	Withstand capabilities and SPD coordination	51
F.3	Common mode to differential mode surge conversion by switching devices	51
F.3.1	General	51
F.3.2	Differential mode voltage reduction by inter-wire protection.....	52
F.3.3	Differential mode voltage reduction by single switching element.....	53
Annex G (informative)	EMC impact of SPDs	55
G.1	General.....	55
G.2	Electromagnetic immunity.....	55
G.3	Electromagnetic emission.....	55

Annex H (informative) Definition of internal port (Source: ITU-T K.44)	56
Annex I (informative) Maintenance of SPDs for Information Technology	57
I.1 General requirements	57
I.2 Maintenance responsibilities	57
I.3 Maintenance of SPDs	57
I.3.1 General	57
I.3.2 Visual inspection	58
I.3.3 Complete inspection	58
I.3.4 Examining periods	58
Annex J (informative) Earth potential rise (EPR)	60
J.1 General	60
J.2 Causes of EPR	60
J.3 Influence of soil resistivity	60
J.4 Fibre optics	60
Annex K (informative) References and examples of risk management based on IEC 62305-2	61
Bibliography	62





Figure 1 – SPD installation in telecommunications and signalling networks	16
Figure 2 – Measurement and Control network (MCR)	16
Figure 3 – Coupling mechanisms	18
Figure 4 – Example of a configuration of the lightning protection concept	20
Figure 5 – Example of a configuration according to the zones (Figure 4)	21
Figure 6 – Example of protection measures against common-mode voltages and differential mode voltages of the data (f) and supply voltage input (g) of an ITE	22
Figure 7 – Influence of voltages U_{L1} and U_{L2} on protection level U_P caused by inductance of the leads	23
Figure 8 – Removal of the voltages U_{L1} and U_{L2} from the protector unit by connecting leads to a common point	24
Figure 9 – Necessary installation conditions of a three, five or multi-terminal SPD with an ITE for minimizing the interference influences on the protection level	25
Figure 10 – Individual SPDs	27
Figure 11 – MSPD with PE connection option	27
Figure 12 – MSPD with transient bonding SPCs to PE terminals	28
Figure 13 – Coordination of two SPDs	29
Figure A.1 – Behaviour of clamping components	30
Figure A.2 – Behaviour of switching components	32
Figure B.1 – Behaviour of current interrupting components	34
Figure B.2 – Behaviour of current-diverting component	35
 Figure B.3 – Thermally operated (heat coil) three-terminal shunt current limiter	36 
Figure B.4 – Behaviour of current-reducing components (thermally operated type)	37
Figure B.5 – Thermally operated (PTC thermistor) two-terminal series current limiting component	38
Figure B.6 – Two-terminal series electronic current limiting component	39
Figure B.7 – Electronic (gated bidirectional thyristor) three-terminal shunt current limiting component	39
Figure C.1 – Risk evaluation procedure	42

Figure E.1 – Coordination verification process	48
Figure F.1 – PoE powering modes.....	50
Figure F.2 – Common mode to differential mode surge conversion by asynchronous SPD operation	51
Figure F.3 – Differential surge generated by asynchronous SPD operation on a longitudinal surge	52
Figure F.4 – SPD circuit with inter-wire protection to limit the differential surge	52
Figure F.5 – Differential surge voltage limited by inter-wire protection	53
Figure F.6 – SPD using a single switching element and a steering diode bridge	53
Figure F.7 – Differential surge voltage reduced by single switching element and steering diode bridge	54
Table 1 – Responsibility for managing the protective measures.....	15
 Table 2 – Coupling mechanisms.....	19
Table 3 – Selection aid for rating SPDs for the use in (zone) interfaces according to IEC 62305-1	21 
Table 4 – Relationship between SPD classification of IEC 61643-21 and IEC 61643-11.....	26
Table 5 – Relationship between LPZ and the requested test categories of MSPDs	28
Table C.1 – AC overhead power systems	43
Table C.2 – AC underground electric cables	43
Table C.3 – DC overhead power systems	44
Table C.4 – DC underground electric cables.....	44
Table D.1 – Transmission characteristics for telecommunications systems in access networks.....	45
Table D.2 – Transmission characteristics of IT systems in customer premises.....	46
Table D.3 – Transmission characteristics of cable TV systems.....	46
Table F.1 – Comparison of Type 1 (PoE) and Type 2 PoE+) powering values.....	50
Table I.1 – Maximum period between inspections of lightning protective measures covered by IEC 62305-3.....	58
Table I.2 – Maximum period between inspections of lightning protective measures covered by ITU-T K.69 [28]	59

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SURGE PROTECTIVE DEVICES –**Part 22: Surge protective devices connected to
telecommunications and signalling networks –
Selection and application principles**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61643-22 has been prepared by subcommittee 37A: Low-voltage surge protective devices, of IEC technical committee 37: Surge arresters.

This second edition cancels and replaces the first edition published in 2004. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Update the use of multiservice SPDs (Article 8)
- b) Comparison between SPD classification of IEC 61643-11 and IEC 61643-21 (7.3.3)
- c) Consideration of new transmission systems as PoE (Annex F)
- d) EMC requirements of SPDs (Annex G)

e) Maintenance cycles of SPDs (Annex I)

The text of this standard is based on the following documents:

FDIS	Report on voting
37A/273/FDIS	37A/277/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

A list of all parts in the IEC 61643 series, published under the general title *Low-voltage surge protector devices*, can be found on the IEC website.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This International Standard is a guide for the application of SPDs to telecommunications and signalling lines and those SPDs which have telecom or signalling SPDs in the same enclosure with power line SPDs (so called multiservice SPDs). Definitions, requirements and test methods are given in IEC 61643-21. The decision to use SPDs is based on an analysis of the risks that are seen by the network or system under consideration. Because telecommunications and signalling systems may depend on long lengths of wire, either buried or aerial, the exposure to overvoltages from lightning, power line faults and power line/load switching, can be significant. If these lines are unprotected, the resultant risk to information technology equipment (ITE) can also be significant. Other factors that may influence the decision to use SPDs are local regulators and insurance stipulations. This standard provides indications for evaluating the need for SPDs, the selection, installation and dimensioning of SPDs and for achieving coordination between SPDs and between SPDs and ITE installed on telecommunication and signal lines.

Coordination of SPDs assures that a proper interaction between them, as well as between an SPD and the ITE to be protected will be realized. Coordination requires that the voltage protection level, U_p , and let-through current, I_p , of the initial SPD does not exceed the resistibility of subsequent SPDs or the ITE.

In general, the SPD closest to the source of the impinging surge diverts most of the surge: a downstream SPD will divert the remaining or residual surge. The coordination of SPDs in a system is affected by the operation of the SPDs and the equipment to be protected as well as the characteristics of the system to which the SPDs are connected.

The following variables should be reviewed when attempting to attain proper coordination:

- waveshape of the impinging surge (impulse or AC);
- ability of the equipment to withstand an overvoltage/overcurrent without damage;
- installation, e.g. distance between SPDs and between SPDs and ITE;
- SPD voltage-protection levels.

The performance of an SPD and its coordination with other SPDs can be affected by exposure to previous transients. This is especially true for transients which approach the limit of the capacity of the SPD. If there is considerable doubt concerning the number and severity of the surges handled by the SPDs under consideration, it is suggested that SPDs with higher capabilities be used.

One of the direct effects of poor coordination may be bypassing of the SPD closest to the surge source, with the result that the following SPD will be forced to handle the entire surge. This can result in damage to that SPD.

Lack of proper coordination can also lead to equipment damage and, in severe cases, may lead to a fire hazard.

There are several technologies used in the design of the SPDs covered in this standard. These are explained in the main text and also in informative Annexes A and B.

LOW-VOLTAGE SURGE PROTECTIVE DEVICES –

Part 22: Surge protective devices connected to telecommunications and signalling networks – Selection and application principles

1 Scope

This part of IEC 61643 describes the principles for the selection, operation, location and coordination of SPDs connected to telecommunication and signalling networks with nominal system voltages up to 1 000 V r.m.s. a.c. and 1 500 V d.c.

This standard also addresses SPDs that incorporate protection for signalling lines and power lines in the same enclosure (so called multiservice SPDs).

2 Normative references

☐ The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 61643-21:2001 + A1:2009 + A2:2013, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods* (IEC 61643-21:2000 + A1:2008, modified + A2:2012)

EN 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems - Requirements and test methods* (IEC 61643-11)

EN 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles* (IEC 61643-12)

EN 62305-1:2011, *Protection against lightning – Part 1: General principles* (IEC 62305-1:2010, modified)

EN 62305-2:2012, *Protection against lightning – Part 2: Risk management* (IEC 62305-2:2010, modified)

EN 62305-3:2011 *Protection against lightning – Part 3: Physical damage to structures and life hazard* (IEC 62305-3:2010, modified)

EN 62305-4:2011 *Protection against lightning – Part 4: Electrical and electronic systems within structures* (IEC 62305-4:2010, modified)

EN 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test* (IEC 61000-4-5) ☐

3 Terms, definitions and abbreviations

For the purposes of this document, the following terms, definitions and abbreviations apply.