



BSI Standards Publication

UHV AC transmission systems

Part 201: UHV AC substation design

National foreword

This Published Document is the UK implementation of IEC TS 63042-201:2018.

The UK participation in its preparation was entrusted to Technical Committee GEL/8, Systems Aspects for Electrical Energy Supply.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2018

Published by BSI Standards Limited 2018

ISBN 978 0 580 97317 8

ICS 29.240.10; 29.240.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 December 2018.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TS 63042-201

Edition 1.0 2018-12

TECHNICAL SPECIFICATION



UHV AC transmission systems – Part 201: UHV AC substation design

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01; 29.240.10

ISBN 978-2-8322-6330-3

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	6
1 Scope	8
2 Normative references	8
3 Terms and definitions	9
4 UHV AC substation requirement	10
4.1 General requirement	10
4.2 System demands	10
4.3 Operation and maintenance requirements	11
4.4 Construction requirements	11
4.5 Site condition	11
4.6 Environmental impact	12
4.7 Economy	12
5 Bus scheme and feeder connection	12
5.1 General	12
5.2 Scheme at high-voltage side of main transformer	13
5.3 Scheme at intermedium-voltage side of main transformer	14
5.4 Scheme at low-voltage side of main transformer	14
5.5 System neutral earthing mode of a UHV AC substation	15
6 Selection of equipment and conductors	16
6.1 General	16
6.1.1 Voltage	16
6.1.2 Rated current	16
6.1.3 Rated frequency	16
6.2 Basic requirements	16
6.2.1 Electrical requirements	16
6.2.2 Mechanical requirements	17
6.2.3 Environmental conditions	17
6.3 Transformer	18
6.4 UHV shunt reactor and neutral-earthing reactor	19
6.5 UHV switchgear	19
6.6 UHV circuit breaker	20
6.7 UHV disconnecter	20
6.8 UHV earthing switch for maintenance	21
6.9 High-speed earthing switch	22
6.10 UHV current transformer	22
6.11 UHV voltage transformer	22
6.12 UHV surge arrester	23
6.13 Reactive power compensation device for low voltage side of UHV transformer	23
6.14 UHV bushing	23
6.15 UHV insulator	24
6.16 UHV conductor	24
6.16.1 General	24
6.16.2 Conductor type	24
6.16.3 Selection of current-carrying capacity (cross-section)	25
6.16.4 Corona and radio interference	25
6.16.5 Mechanical strength	26

7	Equipment layout.....	26
7.1	General requirement of equipment layout.....	26
7.1.1	General	26
7.1.2	Optimization of substation layout	26
7.1.3	Seismic performance	26
7.1.4	Construction, serviceability and reliability and failure response ability.....	26
7.2	Minimum clearances	27
7.2.1	Normal environmental conditions	27
7.2.2	Minimum clearances in air-voltage range	27
7.3	Electromagnetic environment	27
7.3.1	Electrostatic induction mitigation design	27
7.3.2	Magnetic induction mitigation design	28
7.3.3	Audible noise mitigation design	28
7.4	Selection of switchgear equipment.....	29
7.5	Switchgear Installations layout.....	29
7.5.1	General	29
7.5.2	Location arrangement of switchgear	29
7.5.3	Basic arrangement of surge arresters	30
7.5.4	Optimal gas-insulated busbar (GIB) layout and length	30
7.5.5	Utilization of working space for substations	30
7.6	Protection against direct lightning strike.....	31
7.7	Earthing systems	31
7.7.1	General considerations	31
7.7.2	Multiple point earthing method for GIS	32
7.8	Seismic design.....	33
7.8.1	General	33
7.8.2	Basic seismic design	33
7.8.3	Special seismic performance for UHV AC substation equipment	34
8	Control, protection and communication	35
8.1	General.....	35
8.2	Control system.....	35
8.3	Relay protection.....	36
8.3.1	General	36
8.3.2	Duplicated configuration of UHV AC equipment relay protection	36
8.3.3	UHV transformer protection	36
8.4	Communication	37
8.5	Electromagnetic compatibility requirements for control and protection equipment.....	37
9	DC and AC auxiliary power supply system	38
9.1	General.....	38
9.2	DC power supply system.....	38
9.3	AC auxiliary power supply system	38
9.4	AC uninterruptible power supply (UPS) system	39
10	UHV gantry, support and foundation design	39
10.1	UHV gantry and support design	39
10.1.1	General	39
10.1.2	Load and combination of loads	39
10.1.3	Detailing requirements.....	40
10.2	GIS or MTS foundation design	41

Annex A (informative) Load combination of UHV AC equipment	43
Annex B (informative) Specification of UHV AC equipment and conductor	44
Annex C (informative) 1 000 kV outdoor overhead flexible conductor for UHV AC substations in China	46
C.1 General.....	46
C.2 Environmental conditions	46
C.3 Current-carrying capacity and thermal stability check.....	46
C.3.1 Current-carrying capacity check.....	46
C.3.2 Thermal stability check	47
C.4 Determination of bundle spacing	48
C.4.1 General	48
C.4.2 Calculation of maximum electric field strength around conductor	48
C.5 Corona inception voltage	49
C.6 Electric field strength on ground caused by electrostatic induction	50
Annex D (informative) Corona noise reduction measures of a UHV AC substation conductor under the rainy condition in Japan	52
D.1 Basic concept of corona noise reduction	52
D.2 Structure design of UHV AC substation conductor	52
D.3 Design criteria of partial discharge on UHV AC substation conductor	54
D.4 Corona noise measurement of the entrance in UHV AC test station	54
Annex E (informative) Typical examples of items to be considered to select switchgear type	56
Annex F (informative) Standards related to seismic design	58
F.1 Typical seismic guide and standards.....	58
F.2 Comparison of main items among the seismic standards	58
Bibliography.....	59
 Figure 1 – Birds eye view of a typical UHV AC substation	10
Figure 2 – Double busbar (DB) with or without bus section connection.....	13
Figure 3 – One-and-a-half circuit breaker (OHCB)	14
Figure 4 – Two-circuit breaker (2CB)	14
Figure 5 – Example diagram of a bus scheme and feeder connection	15
Figure 6 – Typical configuration of UHV gas-insulated switchgear and crane location	31
Figure 7 – Earthing methods	33
Figure 8 – Flow chart for seismic qualification.....	34
Figure 9 – Example of continuous UHV gantry and independent gantry.....	41
Figure 10 – GIS foundation forms	42
Figure C.1 – Relationship between maximum electric field strength and bundle spacing	49
Figure C.1 – Layout plan of main transformer incoming lines	51
Figure D.1 – Conductor design of UHV AC substation.....	53
 Table 1 – Comparison of a four-legged reactor and HSES	22
Table 2 – Comparison of conductors.....	25
Table A.1 – Example of load combination for UHV AC equipment	43
Table B.1 – UHV voltage specification	44
Table B.2 – Specification of UHV short-circuit current.....	44

Table B.3 – Noise specification	44
Table B.4 – Surge arrester specification applied in different countries	45
Table C.1 – Current-carrying capacity of bundle conductor	47
Table C.2 – Corona inception voltage of conductor	50
Table D.1 – Estimated values of corona noise of UHV AC transmission line.....	53
Table D.2 – Design criteria of partial discharge on UHV AC substation conductor	54
Table D.3 – Results of corona noise measurements and average value of corona noise	55
Table E.1 – The principal technology designs for substations (CIGRE TB 570)	56
Table E.2 – Typical examples of items to be considered to select switchgear type	57
Table F.1 – Typical seismic guide and standards	58
Table F.2 – Comparison of main items among seismic standards.....	58

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UHV AC TRANSMISSION SYSTEMS –**Part 201: UHV AC substation design****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 63042-201, which is a technical specification, has been prepared by IEC technical committee 122: UHV AC transmission systems.

The text of this Technical Specification is based on the following documents:

Enquiry draft	Report on voting
122/64/DTS	122/71A/RVDTS

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 63042 series, published under the general title *UHV AC transmission systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

UHV AC TRANSMISSION SYSTEMS –

Part 201: UHV AC substation design

1 Scope

This part of 63042, which is a Technical Specification, provides common rules for the design of substations with the highest voltages of AC transmission systems exceeding 800 kV, so as to provide safety and proper functioning for the intended use.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60044 (all parts), *Instrument transformers*

IEC 60059:1999, *IEC standard current ratings*
IEC 60059:1999/AMD1:2009

IEC 60071-1:2006, *Insulation co-ordination – Part 1: Definitions, principles and rules*
IEC 60071-1:2006/AMD1:2010

IEC 60071-2, *Insulation co-ordination – Part 2: Application guide*

IEC 60076 (all parts), *Power transformers*

IEC 60068-3-3, *Environmental testing – Part 3: Guidance – Seismic test methods for equipments*

IEC 60137, *Insulated bushings for alternating voltages above 1000 V*

IEC 60168, *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V*

IEC 60196:2009, *IEC standard frequencies*

IEC 60255-26, *Measuring relays and protection equipment – Part 26: Electromagnetic compatibility requirements*

IEC TS 60479-1, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60721-2-4, *Classification of environmental conditions – Part 2-4: Environmental conditions appearing in nature – Solar radiation and temperature*

IEC TS 60815 (all parts), *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions*

IEC 60865 (all parts), *Short-circuit currents*